


Lightning products Earthing systems

Inspection pit

In compliance with **NF EN 50164-4** standard



The inspection pit should be installed in the low part of each down conductor.

It allows disconnecting the Lightning earthing system, the down conductor and the equipotential connection from the main earthing network of the site (electrical network, main board, and so on).

The connection of the different conductors can be done with the following pieces :

- Flat-Round coupling AFJ0819RL



- Control junction AFK0080BC



CHARACTERISTICS

Reference :	AFK 8001 RV
Type of installation :	Earthing system
Assembly :	Installation of the pit, interconnection of the conductors according to the coupling choice
Use :	Interconnections earth conductors
Display :	-
Conductors	-
Material :	Cast iron
Dimensions :	Ø230 x 90 mm
Weight :	4,900 kg
Indice of protection :	-
Standards :	NF EN 50164-4

Last update : 09/12/2014

Franklin Technologie © - A full range of lighting and overvoltage protection.
In the continue framework of its products, **Franklin France** shall be entitled to modify specifications without notice