

### Inspection pit



The inspection pit should be installed in the low part of each down conductor.

It allows disconnecting the Lightning earthing system, the down conductor and the equipotential connection from the main earthing network of the site (electrical network, main board, and so on...).

The connection of the different conductors can be done with the following pieces :

- Flat-Round coupling (AFJ0819RL )



- Control junction (AFK0080BC)



### Caracteristics

<b>Reference :</b>	<b>AFK8001RV</b>
<b>Type of installation :</b>	Earthing system
<b>Assembly :</b>	Installation of the pit, interconnection of the conductors according to the coupling choice
<b>Use :</b>	Interconnections earth conductors
<b>Display :</b>	-
<b>Conductors :</b>	-
<b>Material :</b>	Cast iron
<b>Dimensions :</b>	Ø230 x 90 mm
<b>Weight :</b>	6,430 kg
<b>Load test:</b>	30 KN according to NF EN 62561-5
<b>Standards :</b>	NF EN 62561-5

Franklin Technologie® - A full range of lightning and overvoltage protection.  
In the continue framework of its products, Franklin France shall be entitled to modify specifications without notice